

EMPLOYMENT SERVICES

PROGRAM

THINK SAFETY FIRST



CPPFOUNDATION.COM

Memorandum

Date: January 30, 2012

To: Personnel Committee

Cal Poly Pomona Foundation, Inc.

From: Dennis Miller

Director, Employment Services

Subject: INJURY & ILLNESS PREVENTION PROGRAM 2012

Foundation has an organization wide Injury & Illness Prevention Program (IIPP) more commonly referred to as our Safety Program, which, when working at its peak effectiveness, will reduce injuries and illness associated with the work environment.

The attached IIPP provides the framework in which all safety and/or hazard related programs, initiatives, communications, training, and accident reporting is based within Foundation.

While our IIPP is designed to ensure compliance with SB 288, more importantly, it provides Foundation employees with a "code of safe practices" for the long term purpose of shaping the mindset and subsequent behaviors that results in creating and sustaining a safe work environment.

The objective of our IIPP is not "zero accidents", but rather, "zero behaviors" that ultimately lead to accidents. Still, accidents will happen and the policy outlines the process for reporting accidents as well as record retention, and other administrative duties.

The IIPP is an integral component of our workers compensation program. And although the forms associated with reporting workplace injuries are not included in the attached packet of information, our IIPP is directly tied to how Foundation manages the \$250,000 annual expense associated with workers compensation.

For your information, the key components of our IIPP are attached.



INJURY AND ILLNESS PREVENTION PROGRAM FOR

Cal Poly Pomona Foundation, Inc.

RESPONSIBILITY

The Injury and Illness Prevention Program (IIPP) administrator, <u>Chief Employment Officer</u> has the authority and responsibility for implementing the provisions of this program for <u>Cal Poly Pomona Foundation</u>, <u>Inc</u>. All managers, supervisors and lead personnel are responsible for implementing and maintaining the IIPP in their work areas and for answering worker questions about the Program. A copy of this IIPP is available in <u>3801 W. Temple Ave, Bldg 55, Pomona, CA 91768</u>, and on Foundation's website at www.foundation.cpp.edu

COMPLIANCE

Management is responsible for ensuring that all safety and health policies and procedures are clearly communicated and understood by all employees. Supervisors and lead personnel are expected to enforce the rules fairly and uniformly. All employees are responsible for using safe work practices, for following all directives, policies and procedures, and for assisting in maintaining a safe work environment.

The following is our system of ensuring that all workers comply with the rules and maintain a safe work environment:

- Informing workers of the provisions of our IIPP;
- Evaluating the safety performance of all workers;
- Recognizing employees who perform safe and healthful work practices. This recognition
 is accomplished by: <u>Informal recognition within Foundation and AORMA Recognition</u>
 <u>Programs</u>;
- Providing training to workers whose safety performance is deficient;
- Disciplining workers for failure to comply with safe and healthful work practices. The following outlines our disciplinary process: When it becomes necessary, Foundation reserves the right to discipline employees who knowingly violate company safety rules or policies.
 - o Disciplinary measures will include, but are not limited to:
 - Verbal warning (documented) for minor offenses.
 - Written warning for more severe or repeated violations.
 - Suspension without pay, if verbal and written warnings do not prove to be sufficient.

If none of the above measures achieve satisfactory corrective results, and no other acceptable solution can be found, the Foundation will have no choice but to end the employment for those who continue to jeopardize their own safety and the safety of others.

COMMUNICATION

We recognize that open, two-way communication between management and employee on health and safety issues is essential to an injury-free, productive workplace. The following is our system of communication, designed to facilitate a continuous flow of two-way (management,

supervision and employees) safety and health information in a form that is readily understandable to and between all affected site personnel:

- New worker orientation, including a discussion of site-specific safety and health policies and procedures.
- Follow-through by supervision to ensure effectiveness.
- Workplace-specific safety and health training.
- Formal safety meetings will be held on a quarterly basis at each enterprise jobsite. Informal safety briefings will be conducted weekly depending on the department or site. The quarterly meetings will include supervisors and will last for at least 30 minutes, and will be documented. The weekly meetings will be short (5 10 minutes), and will cover 1-2 specific subjects. Safety meetings are required by CAL/OSHA in order to successfully communicate important information to employees, as well as promote safety awareness. All safety meeting meetings will be documented.
- Effective communication of safety and health concerns between workers and supervisors, including language translation where appropriate.
- Posted and distributed safety information.
- Supervisors will report any unsafe acts or unsafe conditions in writing immediately by submitting a Safety Hazard Notice to the Safety Director. The Safety Director will initiate immediate abatement procedures, either personally or by delegation to one of the Safety Managers. Employee Hazard Reporting Program Employees will also be responsible for reporting any unsafe act or unsafe condition to their supervisor via a written Safety Hazard Notice. The supervisor will then forward the notice on to the Safety Director for handling and disposition.
- Vehicle and site-specific codes of safe work practices.
- An authorized instructor will conduct workplace safety and health training.
- Posting and/or distributing safety information via the newsletter or other Foundation wide communications.
- A suggestion box is available at every enterprise location for workers to report hazards, anonymously, and also inter-office mail directly to the Safety Director can be used for anonymous reports.
- Our organization also uses a labor/management safety and health committee which meets the requirements of <u>T8CCR 3203 (7)(c)(1) (7)</u> to comply with the communication requirements of subsection (a)(3) of T8CCR 3203.

HAZARD ASSESSMENT

Periodic inspections to identify and evaluate workplace hazards shall be performed by the Safety Director, or their designee, according to the following schedule:

- When our Injury and Illness Prevention Program was first established;
- At least quarterly.
- Prior to beginning of the shifts in selected areas;
- When new substances, processes, procedures or equipment that present potential new hazards are introduced into our workplace;
- When new, previously unidentified hazards are recognized;
- When occupational injuries and illnesses occur;

- When we hire and/or reassign permanent or intermittent workers to processes, operations, or tasks for which a hazard evaluation has not been previously conducted; and
- Whenever workplace conditions warrant an inspection.

Periodic inspections consist of identification and evaluation of workplace hazards utilizing applicable sections of the attached Hazard Assessment Checklist, and any other effective methods to identify and evaluate workplace hazards.

ACCIDENT/EXPOSURE INVESTIGATIONS

Investigation of workplace accidents, hazardous substance exposures and near-accidents will be done by Employment Services.

Accident investigation is a systematic method for collecting factual information that makes it possible to accurately reconstruct the accident and determine the underlying reasons for the cause of the accident. The investigation is fact-finding, not fault finding. Once the primary causes for the accident have been determined, preventative measures can be identified and effectively instituted. Each supervisor has a prominent role in conducting an accident investigation. The responsibility for conducting an accident investigation includes collecting the facts, determining the sequence of events that resulted in the accident, identify action to prevent recurrence, and provide follow-up to ensure that corrective action was effective. All accidents should be investigated promptly regardless of their severity. Promptness of the investigation is essential since conditions at the accident scene change. Moreover, witnesses are more likely to relate circumstances as they were, without the added conjecture that comes late from discussions of the accident with other employees. Promptness in checking the scene assures employees that management is highly concerned for their well-being. The type of investigation depends on the nature and magnitude of the accident. Each department supervisor/manager shall promptly investigate, thoroughly analyze, and report in writing to the Safety Director all accidents involving personal injury and/or property damage or the potential there for, once they occur, and will include:

- Visiting the scene as soon as possible;
- Interviewing affected workers and witnesses;
- Examining the workplace for factors associated with the accident/exposure/near-accident;
- Determining the causes of the accident/exposure/near-accident;
- Taking corrective action to prevent the accident/exposure/near-accident from reoccurring; and
- Recording the findings and corrective actions taken on the attached OSHA Form 301.

HAZARD CORRECTION

Unsafe or unhealthy work conditions, practices or procedures at our work facilities shall be corrected **in a timely manner** based on the severity of the hazards, and according to the following procedures:

- When observed or discovered:
- When an imminent hazard exists which cannot be immediately abated without endangering employee(s) and/or property, we will remove all exposed workers from the

- area except those necessary to correct the existing condition. Workers necessary to correct the hazardous condition shall be provided with the necessary protection; and
- All such actions taken and dates they are completed shall be documented on the attached Identified Hazards and Correction Record*.

TRAINING AND INSTRUCTION

All workers, including management, supervisors, and lead personnel shall have training and instruction on general and job-specific safety and health practices. Training and instruction shall be provided as follows:

- When the IIPP is first established;
- To all new workers;
- To all workers given new job assignments for which training has not previously provided;
- Whenever new substances, processes, procedures or equipment are introduced to the workplace and represent a new hazard;
- Whenever we become aware of a new or previously unrecognized hazard;
- To supervisors to familiarize them with the safety and health hazards to which workers under their immediate direction and control may be exposed; and
- To all workers with respect to hazards specific to each employee's job assignment.

This training will include (but is not limited to):

- Explanation of our IIPP, emergency action plan and fire prevention plan, and measures for reporting any unsafe conditions, work practices, injuries and when additional instruction is needed.
- Availability of toilet, hand-washing, and drinking water facilities.
- Provisions for medical services and first aid, including emergency procedures.
- Proper housekeeping, such as keeping stairways and isles clear, work areas neat and orderly, and promptly cleaning up spills.
- Prohibiting horseplay, scuffling, or other acts that adversely influence safety.
- Proper storage to prevent:
 - o stacking goods in an unstable manner
 - o storing materials and good against doors, exits, for extinguishing equipment and electrical panels.

Where applicable our training may also include:

- Prevention of musculoskeletal disorders, including proper lifting techniques.
- Use of appropriate clothing, including gloves, footwear, and personal protective equipment.
- Information about chemical hazards to which employees could be exposed and other hazard communication program information.
- Proper food and beverage storage to prevent them from becoming contaminated.

In addition, we provide specific instructions to all workers regarding hazards unique to their job assignment, to the extent that such information was not already covered in other training.

RECORDKEEPING

Written IIPP and Documentation Requirements

Our organization has ten or more employees and keeps records as follows:

- 1. Records of scheduled and periodic inspections including the person(s) conducting the inspection, the workplace hazards (i.e., unsafe conditions and work practices that have been identified) and the action(s) taken to correct the identified unsafe conditions and work practices, are recorded on the Hazard Assessment Checklist and the Identified Hazards and Correction Record and the Investigation/Corrective Action Report. These records are maintained for at least one (1) year.
- 2. Documentation of safety and health training for each worker, including the worker's name or other identifier, training dates, type(s) of training, and training providers are recorded on the Worker Training and Instruction Record. This documentation is maintained for at least one (1) year.

This Policy was last revised January 2017

LIST OF TRAINING SUBJECTS



We train our workers about the following checked training subjects:

Ļ	Explanation of our Injury and Illness Prevention Program
	Measure for reporting any unsafe conditions, work practices, and injuries
	Provisions for medical services, first aid and emergency service
	The employer's Code of Safe Practices.
	Confined spaces.
	Safe practices for operating any agricultural equipment.
	Good housekeeping, fire prevention, safe practices for operating any construction equipment.
	Safe procedures for cleaning, repairing, servicing and adjusting equipment and machinery.
	Safe access to working areas.
	Protection from falls.
	Electrical hazards, including working around high voltage lines.
	Crane operations.
	Trenching and excavation work.
	Proper use of powered tools.
	Guarding of belts and pulleys, gears and sprockets, and conveyor nip points.
	Machine, machine parts, and prime movers guarding.
	Lock-out/tag-out procedures.
	Materials handling.
	Chainsaw and other power tool operation.
	Tree falling/bucking procedures and precautions, including procedures for recognizing and working with
_	hazard trees, snags, lodged trees, and unsafe weather conditions.
	Yarding operations, including skidding, running lines, unstable logs, rigging and communication.
	Landing and loading areas, including release of rigging, landing layout, moving vehicles and
	equipment, and log truck locating, loading and wrapping.
	Fall protection from elevated locations.
	Use of elevated platforms, including condors and scissor lifts. Safe use of explosives.
_	•
	Driver safety.
	Slips, falls, and back injuries.
	Ergonomic hazards, including proper lifting techniques and working on ladders or in a stooped posture for prolonged periods at one time.
	Personal protective equipment
J	Respiratory Equipment.
	Hazardous chemical exposures.
_	Hazard communication.
	Physical hazards, such as heat/cold stress, noise, and ionizing and non-ionizing radiation.
	Laboratory safety.
_	Bloodborne pathogens and other biological hazards.
	Emergency action and fire prevention plans
	Other job-specific hazards, such as
•	
_	

WORKER TRAINING AND INSTRUCTION RECORD



Date			Location	1.00	200
Trainer(s)*					
Subject of Training*				·	
Method of Training (check all that apply)		Verbal		☐ Video	
		Audio		Other	
Name (Printed) *			Signatu	le .	Employee ID Number

10 10 10 10 10 10 10 10 10 10 10 10 10 1					·
	;				

^{*} Mandatory fields: employee name (or other identification), training date, type of training, and training providers

INVESTIGATION / CORRECTIVE ACTION REPORT



Date and Time of Incident / Exposure	Location	
	EMPLOYEES INVOLVED	
DETAILE	ED INCIDENT / EXPOSURE DESCRIPTION	
ULTIMATE CAUSE OF INCIDENT/EXPO	OSURE (I.E. "WHO, WHAT, WHEN, WHERE, HOW" AND	THE "5 WAYS"
	THE ROOT CAUSE)	
OPTIONS FOR ELIN	MINATION OR CONTROL OF THE ROOT CAUSE(S)	
		į
CORRECTIVE ACTIONS TAKE	EN / DATE / NAME OF PERSON(S) MAKING CORRECT	IONS
		}
Vitnesses:		
nvestigated by:	Date:	

IDENTIFIED HAZARDS AND CORRECTION RECORD

Date of Inspection: Person Conducting Inspection:	
---	--

	ACTION (TE)
	<u>resilve david</u>
į į į į į į į į į į į į į į į į į į į	

HAZARD ASSESSMENT CHECKLIST



The following checklist can be used to identify and evaluate hazards in your workplace. This checklist covers a wide variety of workplace safety and health hazards. All of the topics covered in this checklist may not apply to your particular workplace. When evaluating your workplace use the sections of the checklist that apply to your workplace and work activities.

GENERAL WORK ENVIRONMENT

	Are all worksites clean and orderly?
	Are work surfaces kept dry or appropriate means taken to assure the surfaces are slip-resistant?
	Are all spilled materials or liquids cleaned up immediately?
	Is combustible scrap, debris and waste stored safely and removed from the worksite promptly?
	Is accumulated combustible dust routinely removed from elevated surfaces, including the overhead structure
	of buildings?
	Is combustible dust cleaned up with a vacuum system to prevent the dust going into suspension?
<u> </u>	Is metallic or conductive dust prevented from entering or accumulation on or around electrical enclosures or equipment?
	Are covered metal waste cans used for oily and paint-soaked waste?
	Are all oil and gas fired devices equipped with flame failure controls that will prevent flow of fuel if pilots or main burners are not working?
	Are paint spray booths, dip tanks and the like cleaned regularly?
	Are the minimum number of toilets and washing facilities provided?
	Are all toilets and washing facilities clean and sanitary?
	Are all work areas adequately illuminated?
	Are pits and floor openings covered or otherwise guarded?
	Are pits and moor openings covered or otherwise guarded?
	PERSONAL PROTECTIVE EQUIPMENT
	Are protective goggles or face shields provided and worn where there is any danger of flying particles or
ш	corrosive materials?
	Are approved safety glasses required to be worn at all times in areas where there is a risk of eye injuries such as punctures, abrasions, contusions or burns?
	Are employees who need corrective lenses (glasses or contacts lenses) in working environments with harmful exposures, required to wear only approved safety glasses, protective goggles, or use other medically approved precautionary procedures?
	Are protective gloves, aprons, shields, or other means provided against cuts, corrosive liquids and chemicals?
	Are hard hats provided and worn where danger of falling objects exists?
	Are hard hats inspected periodically for damage to the shell and suspension system?
	Is appropriate foot protection required where there is the risk of foot injuries from hot, corrosive, poisonous
_	substances, falling objects, crushing or penetrating actions?
_	Are approved respirators provided for regular or emergency use where needed?
Ц	Is all protective equipment maintained in a sanitary condition and ready for use?
	Do you have eye wash facilities and a quick drench shower within the work area where employees are
	exposed to injurious corrosive materials?
	Where special equipment is needed for electrical workers, is it available?
	When lunches are eaten on the premises, are they eaten in areas where there is no exposure to toxic materials or other health hazards?
	materials or other nealth nazards? Is protection against the effects of occupational noise exposure provided when sound levels exceed those of
	the Cal/OSHA noise standard?

WALKWAYS ☐ Are aisles and passageways kept clear? ☐ Are aisles and walkways marked as appropriate? ☐ Are wet surfaces covered with non-slip materials? ☐ Are holes in the floor, sidewalk or other walking surface repaired properly, covered or otherwise made safe? ☐ Is there safe clearance for walking in aisles where motorized or mechanical handling equipment is operating. ☐ Are spilled materials cleaned up immediately? ☐ Are materials or equipment stored in such a way that sharp projectiles will not interfere with the walkway? ☐ Are changes of direction or elevations readily identifiable? Are aisles or walkways that pass near moving or operating machinery, welding operations or similar operations arranged so employees will not be subjected to potential hazards? ☐ Is adequate headroom provided for the entire length of any aisle or walkway? ☐ Are standard guardrails provided wherever aisle or walkway surfaces are elevated more than 30 inches above any adjacent floor or the ground? ☐ Are bridges provided over conveyors and similar hazards? FLOOR AND WALL STAIRWAYS ☐ Are floor openings guarded by a cover, guardrail, or equivalent on all sides (except at entrance to stairways or ladders)? Are toeboards installed around the edges of a permanent floor opening (where persons may pass below the opening)? Are skylight screens of such construction and mounting that they will withstand a load of at least 200 pounds? Is the glass in windows, doors, glass walls that are subject to human impact, of sufficient thickness and type for the condition of use? ☐ Are grates or similar type covers over floor openings such as floor drains, of such design that foot traffic or rolling equipment will not be affected by the grate spacing? ☐ Are unused portions of service pits and pits not actually in use either covered or protected by guardrails or equivalent? ☐ Are manhole covers, trench covers and similar covers, plus their supports, designed to carry a truck rear axle load of at least 20,000 pounds when located in roadways and subject to vehicle traffic? ☐ Are floor or wall openings in fire resistive construction provided with doors or covers compatible with the fire rating of the structure and provided with self-closing feature when appropriate? STAIRS & STAIRWAYS ☐ Are standard stair rails or handrails on all stairways having four or more risers? ☐ Are all stairways at least 22 inches wide? ☐ Do stairs have at least a 6'6" overhead clearance? ☐ Do stairs angle no more than 50 and no less than 30 degrees? Are stairs of hollow-pan type treads and landings filled to noising level with solid material? ☐ Are step risers on stairs uniform from top to bottom, with no riser spacing greater than 7-1/2 inches? ☐ Are steps on stairs and stairways designed or provided with a surface that renders them slip resistant? ☐ Are stairway handrails located between 30 and 34 inches above the leading edge of stair treads? ☐ Do stairway handrails have a least 1-1/2 inches of clearance between the handrails and the wall or surface they are mounted on? ☐ Are stairway handrails capable of withstanding a load of 200 pounds, applied in any direction?

☐ Where stairs or stairways exit directly into any area where vehicles may be operated, are adequate barriers

Do stairway landings have a dimension measured in the direction of travel, at least equal to width of the

and warnings provided to prevent employees stepping into the path of traffic?

☐ Is the vertical distance between stairway landings limited to 12 feet or less?

stairway?

ELEVATED SURFACES

	collapsing, rolling or spreading?
	Are all exits marked with an exit sign and illuminated by a reliable light source?
	Are the directions to exits, when not immediately apparent, marked with visible signs?
	Are doors, passageways or stairways, that are neither exits nor access to exits and which could be mistaken for exits, appropriately marked "NOT AN EXIT", "TO BASEMENT", "STOREROOM", and the like?
ł	Are exit signs provided with the word "EXIT" in lettering at least 5 inches high and the stroke of the lettering at least 1/2 inch wide?
	Are exit doors side-hinged?
_	Are all exits kept free of obstructions?
	Are at least two means of egress provided from elevated platforms, pits or rooms where the absence of a
	second exit would increase the risk of injury from hot, poisonous, corrosive, suffocating, flammable, or
	explosive substances? Are there sufficient exits to permit prompt escape in case of emergency?
	Are special precautions taken to protect employees during construction and repair operations?
	appropriate for the building occupancy load?
	Are exit stairways which are required to be separated from other parts of a building enclosed by at least two hour fire-resistive construction in buildings more than four stories in height, and not less than one-hour fire resistive construction elsewhere?
	When ramps are used as part of required exiting from a building, is the ramp slope limited to 1- foot vertical
	and 12 feet horizontal?
	Where exiting will be through frameless glass doors, glass exit doors, storm doors, and such are the doors fully tempered and meet the safety requirements for human impact?
	EXIT DOORS
	Are doors that are required to serve as exits designed and constructed so that the way of exit travel is obvious and direct?
	Are windows that could be mistaken for exit doors, made inaccessible by means of barriers or railings?
_	Are exit doors openable from the direction of exit travel without the use of a key or any special knowledge or effort, when the building is occupied?
	Is a revolving, sliding or overhead door prohibited from serving as a required exit door?
Щ	Where panic hardware is installed on a required exit door, will it allow the door to open by applying a force of 15 pounds or less in the direction of the exit traffic?
	Are doors on cold storage rooms provided with an inside release mechanism that will release the latch and
_	open the door even if it's padlocked or otherwise locked on the outside?
Ш	Where exit doors open directly onto any street, alley or other area where vehicles may be operated, are
	adequate barriers and warnings provided to prevent employees stepping into the path of traffic? Are doors that swing in both directions and are located between rooms where there is frequent traffic, provided
	with viewing panels in each door?

PORTABLE LADDERS

	Are all ladders maintained in good condition, joints between steps and side rails tight, all hardware and fittings securely attached, and moveable parts operating freely without binding or undue play? Are non-slip safety feet provided on each ladder?
	Are non-slip safety feet provided on each metal or rung ladder?
	Are ladder rungs and steps free of grease and oil?
	Is it prohibited to place a ladder in front of doors opening toward the ladder except when the door is blocked open, locked or guarded?
П	Is it prohibited to place ladders on boxes, barrels, or other unstable bases to obtain additional height?
	Are employees instructed to face the ladder when ascending or descending?
	Are employees prohibited from using ladders that are broken, missing steps, rungs, or cleats, broken side rails
	or other faulty equipment?
	Are employees instructed not to use the top 2 steps of ordinary stepladders as a step?
	When portable rung ladders are used to gain access to elevated platforms, roofs, and the like does the ladder always extend at least 3 feet above the elevated surface?
	Is it required that when portable rung or cleat type ladders are used the base is so placed that slipping will not occur, or it is lashed or otherwise held in place?
	Are portable metal ladders legibly marked with signs reading "CAUTION" "Do Not Use Around Electrical Equipment" or equivalent wording?
	Are employees prohibited from using ladders as guys, braces, skids, gin poles, or for other than their intended purposes?
	Are employees instructed to only adjust extension ladders while standing at a base (not while standing on the
,	ladder or from a position above the ladder)?
	Are metal ladders inspected for damage?
Ш	Are the rungs of ladders uniformly spaced at 12 inches, center to center?
	HAND TOOLS & EQUIPMENT
	Are all tools and equipment (both, company and employee-owned) used by employees at their workplace in good condition?
	Are hand tools such as chisels, punches, which develop mushroomed heads during use, reconditioned or
	replaced as necessary?
	replaced as necessary? Are broken or fractured handles on hammers, axes and similar equipment replaced promptly?
	· ·
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition? Are tool handles wedged tightly in the head of all tools?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition? Are tool handles wedged tightly in the head of all tools? Are tool cutting edges kept sharp so the tool will move smoothly without binding or skipping? Are tools stored in dry, secure location where they won't be tampered with?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition? Are tool handles wedged tightly in the head of all tools? Are tool cutting edges kept sharp so the tool will move smoothly without binding or skipping? Are tools stored in dry, secure location where they won't be tampered with? Is eye and face protection used when driving hardened or tempered spuds or nails?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition? Are tool handles wedged tightly in the head of all tools? Are tool cutting edges kept sharp so the tool will move smoothly without binding or skipping? Are tools stored in dry, secure location where they won't be tampered with? Is eye and face protection used when driving hardened or tempered spuds or nails? PORTABLE (POWER OPERATED) TOOLS & EQUIPMENT
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition? Are tool handles wedged tightly in the head of all tools? Are tool cutting edges kept sharp so the tool will move smoothly without binding or skipping? Are tools stored in dry, secure location where they won't be tampered with? Is eye and face protection used when driving hardened or tempered spuds or nails? PORTABLE (POWER OPERATED) TOOLS & EQUIPMENT Are grinders, saws, and similar equipment provided with appropriate safety guards?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition? Are tool handles wedged tightly in the head of all tools? Are tool cutting edges kept sharp so the tool will move smoothly without binding or skipping? Are tools stored in dry, secure location where they won't be tampered with? Is eye and face protection used when driving hardened or tempered spuds or nails? PORTABLE (POWER OPERATED) TOOLS & EQUIPMENT Are grinders, saws, and similar equipment provided with appropriate safety guards? Are power tools used with the correct shield, guard or attachment recommended by the manufacturer?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition? Are tool handles wedged tightly in the head of all tools? Are tool cutting edges kept sharp so the tool will move smoothly without binding or skipping? Are tools stored in dry, secure location where they won't be tampered with? Is eye and face protection used when driving hardened or tempered spuds or nails? PORTABLE (POWER OPERATED) TOOLS & EQUIPMENT Are grinders, saws, and similar equipment provided with appropriate safety guards? Are power tools used with the correct shield, guard or attachment recommended by the manufacturer? Are porlable circular saws equipped with guards above and below the base shoe?
	Are broken or fractured handles on hammers, axes and similar equipment replaced promptly? Are worn or bent wrenches replaced regularly? Are appropriate handles used on files and similar tools? Are employees made aware of the hazards caused by faulty or improperly used hand tools? Are appropriate safety glasses, face shields, and similar equipment used while using hand tools or equipment that might produce flying materials or be subject to breakage? Are jacks checked periodically to assure they are in good operating condition? Are tool handles wedged tightly in the head of all tools? Are tool cutting edges kept sharp so the tool will move smoothly without binding or skipping? Are tools stored in dry, secure location where they won't be tampered with? Is eye and face protection used when driving hardened or tempered spuds or nails? PORTABLE (POWER OPERATED) TOOLS & EQUIPMENT Are grinders, saws, and similar equipment provided with appropriate safety guards? Are power tools used with the correct shield, guard or attachment recommended by the manufacturer?

	Are all cord-connected, electrically operated tools and equipment effectively grounded or of the approved
	double insulated type? Are effective guards in place over belts, pulleys, chains, and sprockets, on equipment such as concrete
	mixers, air compressors, and the like?
	Are portable fans provided with full guards or screens having openings 1/2 inch or less?
	Is hoisting equipment available and used for lifting heavy objects, and are hoist ratings and characteristics appropriate for the task?
	Are ground-fault circuit interrupters provided on all temporary electrical 15 and 20 ampere circuits, used during periods of construction?
	Are pneumatic and hydraulic hoses on power-operated tools checked regularly for deterioration or damage?
	ABRASIVE WHEEL EQUIPMENT GRINDERS
	Is the work rest used and kept adjusted to within 1/8 inch of the wheel?
	Do side guards cover the spindle, nut, and flange and 75 percent of the wheel diameter?
_	The Fernand personal gilladio politically induition:
*	Are goggles or face shields always worn when grinding?
	Is the maximum RPM rating of each abrasive wheel compatible with the RPM rating of the grinder motor? Are fixed or permanently mounted grinders connected to their electrical supply system with metallic conduit or other permanent wiring method?
	Does each grinder have an individual on and off control switch?
	Is each electrically operated grinder effectively grounded?
	Before new abrasive wheels are mounted, are they visually inspected and ring tested?
	Are dust collectors and powered exhausts provided on grinders used in operations that produce large amounts
	of dust?
	Are splashguards mounted on grinders that use coolant, to prevent the coolant reaching employees?
Ц	Is cleanliness maintained around grinder?
	POWDER ACTUATED TOOLS
	Are employees who operate powder-actuated tools trained in their use and carry a valid operator's card?
Ш	Do the powder-actuated tools being used have written approval of the Division of Occupational Safety and Health?
	Is each powder-actuated tool stored in its own locked container when not being used?
□ ₁	Is a sign at least 7" by 10" with bold type reading "POWDER-ACTUATED TOOL IN USE" conspicuously posted when the tool is being used?
	Are powder-actuated tools left unloaded until they are actually ready to be used?
	Are powder-actuated tools inspected for obstructions or defects each day before use?
] 	Do powder-actuated tools operators have and use appropriate personal protective equipment such as hard nats, safety goggles, safety shoes and ear protectors?
Ī	MACHINE GUARDING
	s there a training program to instruct employees on safe methods of machine operation?
	s there adequate supervision to ensure that employees are following safe machine operating procedures?
	s there a regular program of safety inspection of machinery and equipment?
	s all machinery and equipment kept clean and properly maintained?
	s sufficient clearance provided around and between machines to allow for safe operations, set up and
_ s	ervicing, material handling and waste removal?
n	s equipment and machinery securely placed and anchored, when necessary to prevent tipping or other novement that could result in personal injury?
	s there a power shut-off switch within reach of the operator's position at each machine?
	Can electric power to each machine be locked out for maintenance, repair, or security?

	Are the noncurrent-carrying metal parts of electrically operated machines bonded and grounded?
	Are foot-operated switches guarded or arranged to prevent accidental actuation by personnel or falling
	Are manually operated valves and switches controlling the operation of equipment and machines clearly
_	identified and readily accessible?
	Are all emergency stop buttons colored red?
L	Are all pulleys and belts that are within 7 feet of the floor or working level properly guarded?
	Are all moving chains and gears properly guarded?
	Are splashguards mounted on machines that use coolant, to prevent the coolant from reaching employees?
	Are methods provided to protect the operator and other employees in the machine area from hazards created
	at the point of operation, ingoing nip points, rotating parts, flying chips, and sparks?
	Are machinery guards secure and so arranged that they do not offer a hazard in their use?
	If special hand tools are used for placing and removing material, do they protect the operator's hands?
	Are revolving drums, barrels, and containers required to be guarded by an enclosure that is interlocked with
	the drive mechanism, so that revolution cannot occur unless the guard enclosure is in place, so guarded?
	Do arbors and mandrels have firm and secure bearings and are they free from play?
	Are provisions made to prevent machines from automatically starting when power is restored after a power
	failure or shutdown?
	Are machines constructed so as to be free from excessive vibration when the largest size tool is mounted and
	run at full speed?
Ш	If machinery is cleaned with compressed air, is air pressure controlled and personal protective equipment or
	other safeguards used to protect operators and other workers from eye and body injury?
ш	Are fan blades protected with a guard having openings no larger than 1/2 inch, when operating within 7 feet of the floor?
	Are saws used for ripping, equipped with anti-kick back devices and spreaders?
	Are radial arm saws so arranged that the cutting head will gently return to the back of the table when
لسا	released?
	releaseu :
	LOCKOUT BLOCKOUT PROCEDURES
	Is all machinery or equipment capable of movement, required to be de-energized or disengaged and blocked
	or locked out during cleaning, servicing, adjusting or setting up operations, whenever required?
	Is the locking-out of control circuits in lieu of locking-out main power disconnects prohibited?
	Are all equipment control valve handles provided with a means for locking-out?
	Does the lockout procedure require that stored energy (i.e. mechanical, hydraulic, air,) be released or blocked
	before equipment is locked-out for repairs?
	Are appropriate employees provided with individually keyed personal safety locks?
	Are employees required to keep personal control of their key(s) while they have safety locks in use?
	Is it required that employees check the safety of the lock out by attempting a start up after making sure no one
	is exposed?
	Where the power disconnecting means for equipment does not also disconnect the electrical control circuit:
	Are the appropriate electrical enclosures identified?
Ш	Is means provide to assure the control circuit can also be disconnected and locked out?
	WEI DING CUTTING & DDATING
	WELDING, CUTTING & BRAZING
Ц	Are only authorized and trained personnel permitted to use welding, cutting or brazing equipment?
	Do all operator have a copy of the appropriate operating instructions and are they directed to follow them?
	Do all operator have a copy of the appropriate operating instructions and are they directed to follow them? Are compressed gas cylinders regularly examined for obvious signs of defects, deep rusting, or leakage?
	Do all operator have a copy of the appropriate operating instructions and are they directed to follow them? Are compressed gas cylinders regularly examined for obvious signs of defects, deep rusting, or leakage? Is care used in handling and storage of cylinders, safety valves, relief valves, and the like, to prevent damage? Are pregautions taken to prevent the mixture of air or oxygen with flammable gases, except at a burner or in a
	Do all operator have a copy of the appropriate operating instructions and are they directed to follow them? Are compressed gas cylinders regularly examined for obvious signs of defects, deep rusting, or leakage? Is care used in handling and storage of cylinders, safety valves, relief valves, and the like, to prevent damag e?

å

	Are only approved apparatus (torches, regulators, pressure-reducing valves, acetylene generators, manifolds)
_	used? Are cylinders kept away from sources of heat?
,	
	Are empty cylinders appropriately marked their valves closed and valve-protection caps on?
	Are signs reading: DANGER NO-SMOKING, MATCHES, OR OPEN LIGHTS, or the equivalent posted?
Ll	Are cylinders, cylinder valves, couplings, regulators, hoses, and apparatus keep free of oily or greasy substances?
	Is care taken not to drop or strike cylinders?
	Unless secured on special trucks, are regulators removed and valve-protection caps put in place before
	moving cylinders? Do cylinders without fixed hand wheels have keys, handles, or non-adjustable wrenches on stem valves when in service?
	Are liquefied gases stored and shipped valve-end up with valve covers in place?
	Are employees instructed to never crack a fuel-gas cylinder valve near sources of ignition?
	Before a regulator is removed, is the valve closed and gas released form the regulator?
_	and air hose?
	Are pressure-reducing regulators used only for the gas and pressures for which they are intended?
	Is open circuit (No Load) voltage of arc welding and cutting machines as low as possible and not in excess of
П	the recommended limits?
	Under wet conditions, are automatic controls for reducing no-load voltage used?
<u> </u>	Is grounding of the machine frame and safety ground connections of portable machines checked periodically?
	Are electrodes removed from the holders when not in use?
	Is it required that electric power to the welder be shut off when no one is in attendance?
	Is suitable fire extinguishing equipment available for immediate use?
	Is the welder forbidden to coil or loop welding electrode cable around his body?
	Are well machines thoroughly dried and tested before being used?
	Are work and electrode lead cables frequently inspected for wear and damage, and replaced when needed?
	Do means for connecting cables' lengths have adequate insulation?
	When the object to be welded cannot be moved and fire hazards cannot be removed, are shields used to confineheat, sparks, and slag?
	Are firevatchers assigned when welding or cutting is performed, in locations where a serious fire might develop?
	Are combustible floors kept wet, covered by damp sand, or protected by fire-resistant shields?
	When floors are wet down, are personnel protected from possible electrical shock?
	When velding is done on metal walls, are precautions taken to protect combustibles on the other side?
	Before not work is begun, are used drums, barrels, tanks, and other containers so thoroughly cleaned that no substances remain that could explode, ignite, or produce toxic vapors?
	Is it required that eye protection helmets, hand shields and goggles meet appropriate standards?
	Are employees exposed to the hazards created by welding, cutting, or bracing operations protected with personal protective equipment and clothing?
	is a chek made for adequate ventilation in and where welding or cutting is preformed?
	When ∖orking in confined places are environmental monitoring tests taken and means provided for quick removalof welders in case of an emergency?
ı	COMP RESSORS & COMPRESSED AIR
	Are corpressors equipped with pressure relief valves, and pressure gauges?
	Are corpressor air intakes installed and equipped to ensure that only clean uncontaminated air enters the
(compresor?
	Are air ilters installed on the compressor intake?

[Are compressors operated and lubricated in accordance with the manufacturer's recommendations?
	☐ Are safety devices on compressed air systems checked frequently?
E	Before any repair work is done on the pressure system of a compressor, is the pressure bled off and the system locked-out?
Ī	Are signs posted to warn of the automatic starting feature of the compressors?
	Is the belt drive system totally enclosed to provide protection for the front, back, top, and sides?
	Is it strictly prohibited to direct compressed air towards a person?
	Are employees prohibited from using highly compressed air for cleaning purposes?
Ε	
	When using compressed air for cleaning, do employees use personal protective equipment?
	Are safety chains or other suitable locking devices used at couplings of high pressure hose lines where a connection failure would create a hazard?
	Before compressed air is used to empty containers of liquid, is the safe working pressure of the container checked?
	When compressed air is used with abrasive blast cleaning equipment, is the operating valve a type that must be held open manually?
	When compressed air is used to inflate auto tires, is a clip-on chuck and an inline regulator preset to 40 psi required?
	Is it prohibited to use compressed air to clean up or move combustible dust if such action could cause the dust to be suspended in the air and cause a fire or explosion hazard?
	COMPRESSED AIR RECEIVERS
	Is every receiver equipped with a pressure gauge and with one or more automatic, spring-loaded safety valves?
	Is the total relieving capacity of the safety valve capable of preventing pressure in the receiver from
	exceeding the maximum allowable working pressure of the receiver by more than 10 percent?
	Is every air receiver provided with a drainpipe and valve at the lowest point for the removal of accumulated oil and water?
	Are compressed air receivers periodically drained of moisture and oil?
	Are all safety valves tested frequently and at regular intervals to determine whether they are in good operating condition?
	Is there a current operating permit issued by the Division of Occupational Safety and Health?
	Is the inlet of air receivers and piping systems kept free of accumulated oil and carbonaceous materials?
	COMPRESSED GAS & CYLINDERS
	Are cylinders with a water weight capacity over 30 pounds equipped with means for connecting a valve
	protector device, or with a collar or recess to protect the valve? Are cylinders legibly marked to clearly identify the gas contained?
	Are compressed gas cylinders stored in areas which are protected from external heat sources such as flame
	impingement, intense radiant heat, electric arcs, or high temperature lines?
	Are cylinders located or stored in areas where they will not be damaged by passing or falling objects, or subject to tampering by unauthorized persons?
	Are cylinders stored or transported in a manner to prevent them creating a hazard by tipping, falling or rolling?
	Are cylinders containing liquefied fuel gas, stored or transported in a position so that the safety relief device is
	always in direct contact with the vapor space in the cylinder? Are valve protectors always placed on cylinders when the cylinders are not in use or connected for use?
	Are all valves closed off before a cylinder is moved, when the cylinder is empty, and at the completion of each job?
	Are low pressure fuel-gas cylinders checked periodically for corrosion, general distortion, cracks, or any other
	defect that might indicate a weakness or render it unfit for service? Does the periodic check of low pressure fuel-gas cylinders include a close inspection of the cylinders' bottom?
	· · · · · · · · · · · · · · · · · · ·

HOIST & AUXILIARY EQUIPMENT

	Is each overhead electric hoist equipped with a limit device to stop the hook travel at its highest and lowest point of safe travel?
	Will each hoist automatically stop and hold any load up to 125 percent of its rated load, if its actuating force is removed?
	Is the rated load of each hoist legibly marked and visible to the operator?
_	Are stops provided at the safe limits of travel for trolley hoist?
	Are the controls of hoists plainly marked to indicate the direction of travel or motion?
	Is each cage-controlled hoist equipped with an effective warning device?
	Are close-fitting guards or other suitable devices installed on hoist to assure hoist ropes will be maintained in the sheave groves?
	Are all hoist chains or ropes of sufficient length to handle the full range of movement for the application while still maintaining two full wraps on the drum at all times?
	Are nip points or contact points between hoist ropes and sheaves which are permanently located within 7 feet of the floor, ground or working platform, guarded?
	Is it prohibited to use chains or rope slings that are kinked or twisted?
	Is it prohibited to use the hoist rope or chain wrapped around the load as a substitute, for a sling?
	Is the operator instructed to avoid carrying loads over people?
	Are only employees who have been trained in the proper use of hoists allowed to operate them?
	INDUSTRIAL TRUCKS - FORKLIFTS
	Are only trained personnel allowed to operate industrial trucks?
	Is substantial overhead protective equipment provided on high lift rider equipment?
	Are the required lift truck operating rules posted and enforced?
	Is directional lighting provided on each industrial truck that operates in an area with less than 2 foot candles
	per square foot of general lighting?
	Does each industrial truck have a warning horn, whistle, gong or other device which can be clearly heard above the normal noise in the areas where operated?
	Are the brakes on each industrial truck capable of bringing the vehicle to a complete and safe stop when fully
_	loaded?
	Will the industrial truck's parking brake effectively prevent the vehicle from moving when unattended?
	Are industrial trucks operating in areas where flammable gases or vapors, or combustible dust or ignitable fibers may be present in the atmosphere, approved for such locations?
	Are motorized hand and hand/rider trucks so designed that the brakes are applied, and power to the drive motor shuts off when the operator releases his/her grip on the device that controls the travel?
	Are industrial trucks with internal combustion engine operated in buildings or enclosed areas, carefully checked to ensure such operations do not cause harmful concentration of dangerous gases or fumes?
	SPRAYING OPERATIONS
_	Is adequate ventilation assured before spray operations are started?
_	Is mechanical ventilation provided when spraying operation is done in enclosed areas?
_	When mechanical ventilation is provided during spraying operations, is it so arranged that it will not circulate
	the contaminated air?
	Is the spray area free of hot surfaces?
	Is the spray area at least 20 feet from flames, sparks, operating electrical motors and other ignition sources?
	Are portable lamps used to illuminate spray areas suitable for use in a hazardous location?
	Is approved respiratory equipment provided and used when appropriate during spraying operations?
]	Do solvents used for cleaning have a flash point of 100E F or more?
] ,	Are fire control sprinkler heads kept clean?

	Are "NO SMOKING" signs posted in spray areas, paint rooms, paint booths, and paint storage areas?
	Is the spray area kept clean of combustible residue?
	Are spray booths constructed of metal, masonry, or other substantial noncombustible material?
	Are spray booth floors and baffles noncombustible and easily cleaned?
	Is infrared drying apparatus kept out of the spray area during spraying operations?
	Is the spray booth completely ventilated before using the drying apparatus?
	ls the electric drying apparatus properly grounded?
	Are lighting fixtures for spray booths located outside of the booth and the interior lighted through sealed clear panels?
	Are the electric motors for exhaust fans placed outside booths or ducts?
	Are belts and pulleys inside the booth fully enclosed?
	Do ducts have access doors to allow cleaning?
	Do all drying spaces have adequate ventilation?
	ENTERING CONFINED SPACES
	Are confined spaces thoroughly emptied of any corrosive or hazardous substances, such as acids or caustics, before entry?
	Before entry, are all lines to a confined space, containing inert, toxic, flammable, or corrosive materials valved off and blanked or disconnected and separated?
	Is it required that all impellers, agitators, or other moving equipment inside confined spaces be locked-out if they present a hazard?
	Is either natural or mechanical ventilation provided prior to confined space entry?
	· · · · · · · · · · · · · · · · · · ·
	explosive concentrations in the confined space before entry?
	Is the atmosphere inside the confined space frequently tested or continuously monitor during conduct of work?
	Is there an assigned safety standby employee outside of the confined space, whose sole responsibility is to
	watch the work in progress, sound an alarm if necessary, and render assistance?
Ш	the min and anti-plant and ambient and anti-plant a
П	respiratory equipment if there is any questions as to the cause of an emergency? In addition to the standby employee, is there at least one other trained rescuer in the vicinity?
	Are all rescuers appropriately trained and using approved, recently inspected equipment?
	Does all rescue equipment allow for lifting employees vertically from a top opening?
	Are there trained personnel in First Aid and CPR immediately available?
	Is there an effective communication system in place whenever respiratory equipment is used and the
	employee in the confined space is out of sight of the standby person?
	Is approved respiratory equipment required if the atmosphere inside the confined space cannot be made
	acceptable?
Ц	Is all portable electrical equipment used inside confined spaces either grounded and insulated, or equipped with ground fault protection?
	Before gas welding or burning is started in a confined space, are hoses checked for leaks, compressed gas
	bottles forbidden inside of the confined space, torches lighted only outside of the confined area and the
	confined area tested for an explosive atmosphere each time before a lighted torch is to be taken into the confined space?
	If employees will be using oxygen-consuming equipment such as salamanders, torches, furnaces, in a
	confined space, is sufficient air provided to assure combustion without reducing the oxygen concentration of
	the atmosphere below 19.5 percent by volume?
lJ	Whenever combustion-type equipment is used in confined space, are provisions made to ensure the exhaust gases are vented outside of the enclosure?
	Is each confined space checked for decaying vegetation or animal matter, which may produce methane?
	Is the confined space checked for possible industrial waste, which could contain toxic properties?

	If the confined space is below the ground and near areas where motor vehicles will be operating, is it possible for vehicle exhaust or carbon monoxide to enter the space?
	ENVIRONMENTAL CONTROLS
	Are all work areas properly illuminated?
	Are employees instructed in proper first aid and other emergency procedures?
	Are hazardous substances identified which may cause harm by inhalation, ingestion, skin absorption or contact?
	Are employees aware of the hazards involved with the various chemicals they may be exposed to in their work environment, such as ammonia, chlorine, epoxies, and caustics? Is employee exposure to chemicals in the workplace kept within acceptable levels?
	Can a less harmful method or product be used?
_	Is the work area's ventilation system appropriate for the work being performed?
	Are spray painting operations done in spray rooms or booths equipped with an appropriate exhaust system?
	Is employee exposure to welding fumes controlled by ventilation, use of respirators, exposure time, or other means?
	Are welders and other workers nearby provided with flash shields during welding operations?
	If forklifts and other vehicles are used in buildings or other enclosed areas, are the carbon monoxide levels kept below maximum acceptable concentration?
	Has there been a determination that noise levels in the facilities are within acceptable levels?
	Are steps being taken to use engineering controls to reduce excessive noise levels?
Ш	
Ш	Are caution labels and signs used to warn of asbestos?
	Are wet methods used, when practicable, to prevent the emission of airborne asbestos fibers, silica dust and similar hazardous materials?
	Is vacuuming with appropriate equipment used whenever possible rather than blowing or sweeping dust? Are grinders, saws, and other machines that produce respirable dusts vented to an industrial collector or central exhaust system?
	Are all local exhaust ventilation systems designed and operating properly such as airflow and volume necessary for the application? Are the ducts free of obstructions or the belts slipping?
	Is personal protective equipment provided, used and maintained wherever required?
	Are there written standard operating procedures for the selection and use of respirators where needed?
	Are restrooms and washrooms kept clean and sanitary?
	Is all water provided for drinking, washing, and cooking potable?
	Are all outlets for water not suitable for drinking clearly identified?
	Are employees' physical capacities assessed before being assigned to jobs requiring heavy work?
	Are employees instructed in the proper manner of lifting heavy objects?
	Where heat is a problem, have all fixed work areas been provided with spot cooling or air conditioning?
	Are employees screened before assignment to areas of high heat to determine if their health condition might make them more susceptible to having an adverse reaction?
أـــا	Are employees working on streets and roadways where they are exposed to the hazards of traffic, required to
	wear bright colored (traffic orange) warning vest? Are exhaust stacks and air intakes located that contaminated air will not be recirculated within a building or other enclosed area?
	is equipment producing ultra-violet radiation properly shielded?
	FLAMMABLE & COMBUSTIBLE MATERIALS
	Are combustible scrap, debris and waste materials (i.e. oily rags) stored in covered metal receptacles and
	removed from the worksite promptly? Is proper storage practiced to minimize the risk of fire including spontaneous combustion?
	Are approved containers and tanks used for the storage and handling of flammable and combustible liquids?

	Are all connections on drums and combustible liquid piping, vapor and liquid tight?					
	Are all flammable liquids kept in closed containers when not in use (e.g. parts cleaning tanks, pans)?					
	Are bulk drums of flammable liquids grounded and bonded to containers during dispensing?					
	Do storage rooms for flammable and combustible liquids have explosion-proof lights?					
	· · · · · · · · · · · · · · · · · · ·					
	Are all solvent wastes and flammable liquids kept in fire-resistant covered containers until they are removed					
	from the worksite?					
	Is vacuuming used whenever possible rather than blowing or sweeping combustible dust?					
	Are fire separators placed between containers of combustibles or flammables, when stacked one upon					
	another, to assure their support and stability?					
Ш	Are fuel gas cylinders and oxygen cylinders separated by distance, fire resistant barriers or other means while					
	in storage? Are fire extinguishers releated and provided for the tunes of meterials in cross where they are to be used.					
	Are fire extinguishers selected and provided for the types of materials in areas where they are to be used? Class A: Ordinary combustible material fires.					
	Class B: Flammable liquid, gas or grease fires.					
	Class C: Energized-electrical equipment fires.					
	If a Halon 1301 fire extinguisher is used, can employees evacuate within the specified time for that					
JI	extinguisher?					
	Are appropriate fire extinguishers mounted within 75 feet of outside areas containing flammable liquids, and					
	within 10 feet of any inside storage area for such materials?					
	Is the transfer/withdrawal of flammable or combustible liquids performed by trained personnel?					
	Are fire extinguishers mounted so that employees do not have to travel more than 75 feet for a class "A" fire					
$\overline{}$	or 50 feet for a class "B" fire?					
	Are employees trained in the use of fire extinguishers?					
	Are extinguishers free from obstructions or blockage?					
	Are all extinguishers serviced, maintained and tagged at intervals not to exceed one year?					
	Are all extinguishers fully charged and in their designated places?					
	Is a record maintained of required monthly checks of extinguishers?					
<u></u>	Where sprinkler systems are permanently installed, are the nozzle heads directed or arranged so that water will not be sprayed into operating electrical switchboards and equipment?					
	Are "NO SMOKING" signs posted where appropriate in areas where flammable or combustible materials are					
	used or stored?					
	Are "NO SMOKING" signs posted on liquefied petroleum gas tanks?					
	Are "NO SMOKING" rules enforced in areas involving storage and use of flammable materials?					
	Are safety cans used for dispensing flammable or combustible liquids at a point of use?					
	Are all spills of flammable or combustible liquids cleaned up promptly?					
	Are storage tanks adequately vented to prevent the development of excessive vacuum or pressure as a result					
_	of filling, emptying, or atmosphere temperature changes?					
	Are storage tanks equipped with emergency venting that will relieve excessive internal pressure caused by fire					
	exposure? Are spare portable or butane tanks, which are sued by industrial trucks stored in accord with regulations?					
	Are spelle portable of buttarie tariks, which are sued by industrial trucks stored in accord with regulations?					
	FIRE PROTECTION					
	Do you have a fire prevention plan?					
	Does your plan describe the type of fire protection equipment and/or systems?					
	Have you established practices and procedures to control potential fire hazards and ignition sources?					
_	Are employees aware of the fire hazards of the material and processes to which they are exposed?					
	Is your local fire department well acquainted with your facilities, location and specific hazards?					
_	If you have a fire alarm system, is it tested at least annually?					

	If you have a fire alarm system, is it certified as required?				
	If you have interior standpipes and valves, are they inspected regularly?				
	If you have outside private fire hydrants, are they flushed at least once a year and on a routine preventive				
maintenance schedule? Are fire doors and shutters in good operating condition?					
	Are fire doors and shutters unobstructed and protected against obstructions, including their counterweights?				
	Are fire doors and shutter fusible links in place?				
	Are automatic sprinkler system water control valves, air and water pressures checked weekly/periodically as required?				
	Is maintenance of automatic sprinkler system assigned to responsible persons or to a sprinkler contractor? Are sprinkler heads protected by metal guards, when exposed to physical damage?				
	Are portable fire extinguishers provided in adequate number and type?				
	Are fire extinguishers mounted in readily accessible locations?				
	Are fire extinguishers recharged regularly and noted on the inspection tag?				
	Are employees periodically instructed in the use of extinguishers and fire protection procedures?				
	HAZARDOUS CHEMICAL EXPOSURES				
	Are employees trained in the safe handling practices of hazardous chemicals such as acids, caustics, and the like?				
	Are employees aware of the potential hazards involving various chemicals stored or used in the workplace—such as acids, bases, caustics, epoxies, and phenois?				
	☐ Is employee exposure to chemicals kept within acceptable levels?				
	☐ Are eye wash fountains and safety showers provided in areas where corrosive chemicals are handled?				
	Are all containers, such as vats and storage tanks labeled as to their contentse.g. "CAUSTICS"?				
	Are all employees required to use personal protective clothing and equipment when handling chemicals (i.e. gloves, eye protection, and respirators)?				
	Are flammable or toxic chemicals kept in closed containers when not in use?				
	Are chemical piping systems clearly marked as to their content?				
	Where corrosive liquids are frequently handled in open containers or drawn from storage vessels or pipelines,				
	is adequate means readily available for neutralizing or disposing of spills or overflows properly and safely? Have standard operating procedures been established and are they being followed when cleaning up chemical				
	spills?				
	Where needed for emergency use, are respirators stored in a convenient, clean and sanitary location?				
	Are respirators intended for emergency use adequate for the various uses for which they may be needed? Are employees prohibited from eating in areas where hazardous chemicals are present?				
	Is personal protective equipment provided, used and maintained whenever necessary?				
	Are there written standard operating procedures for the selection and use of respirators where needed?				
	If you have a respirator protection program, are your employees instructed on the correct usage and				
П	limitations of the respirators? Are the respirators NIOSH approved for this particular application?				
	Are they regularly inspected and cleaned sanitized and maintained?				
	If hazardous substances are used in your processes, do you have a medical or biological monitoring system in operation?				
	Are you familiar with the Threshold Limit Values or Permissible Exposure Limits of airborne contaminants and physical agents used in your workplace?				
	Have control procedures been instituted for hazardous materials, where appropriate, such as respirators,				
	ventilation systems, handling practices, and the like? Whenever possible, are hazardous substances handled in properly designed and exhausted booths or similar				
	locations?				
	Do you use general dilution or local exhaust ventilation systems to control dusts, vapors, gases, fumes, smoke, solvents or mists which may be generated in your workplace?				

they use solvents or other chemicals? Is there a dermatitis problem—do employees complain about skin dryness, irritation, or sensitization? Have you considered the use of an industrial hygienist or environmental health specialist to evaluate your operation? If internal combustion engines are used, is carbon monoxide kept within acceptable levels?				
HAZARDOUS SUBSTANCES COMMUNICATION				
Is there a written hazard communication program dealing with Material Safety Data Sheets (MSDS) labeling, and employee training? Who is responsible for MSDSs, container labeling, employee training? Is each container for a hazardous substance (i.e. vats, bottles, storage tanks,) labeled with product identity and a hazard warning (communication of the specific health hazards and physical hazards)? Is there a Material Safety Data Sheet readily available for each hazardous substance used? How will you inform other employers whose employees share the same work area where the hazardous substances are used? Is there an employee training program for hazardous substances? Does this program include: An explanation of what an MSDS is and how to use and obtain one? MSDS contents for each hazardous substance or class of substances? Explanation of "Right to Know"?				
ELECTRICAL				
connection with electrical equipment or lines? Are employees instructed to make preliminary inspections and/or appropriate tests to determine what conditions exist before starting work on electrical equipment or lines? When electrical equipment or lines are to be serviced, maintained or adjusted, are necessary switches opened, locked-out and tagged whenever possible? Are portable electrical tools and equipment grounded or of the double insulated type? Are electrical appliances such as vacuum cleaners, polishers, vending machines grounded? Do extension cords being used have a grounding conductor? Are multiple plug adapters prohibited? Are ground-fault circuit interrupters installed on each temporary 15 or 20 ampere, 120 volt AC circuit at locations where construction, demolition, modifications, alterations or excavations are being performed? Are all temporary circuits protected by suitable disconnecting switches or plug connectors at the junction with				
permanent wiring? Is exposed wiring and cords with fraved or deteriorated insulation renaized or replaced promotiv?				

Are flexible cords and cables free of splices or taps?	Are clamps or other securing means provided on flexible cords or cables at plugs, receptacles, tools, and equipment and is the cord jacket securely held in place? Are all cord, cable and raceway connections intact and secure? In wet or damp locations, are electrical tools and equipment appropriate for the use or location or otherwise protected? Is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting wistches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are electrical enclosures such as switches receptacles, junction boxes, etc., provided with tight-fi) in nt					
equipment and is the cord jacket securely held in place? Are all cord, cable and raceway connections intact and secure? In wet or damp locations, are electrical tools and equipment appropriate for the use or location or otherwise profeoted? Is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls) determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come in contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are all connecting means always opened before fluses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and sale operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and filtings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be ho	equipment and is the cord jacket securely held in place? Are all cord, cable and raceway connections intact and secure? In wet or damp locations, are electrical tools and equipment appropriate for the use or location or otherwise protected? Is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are all detectrical means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosurers? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are delectrical protection provided in the control device of motors driving machines or equipment, which cocause probably injury from inadvertent starting? Is low voltage protection provided in the controller or the contr) in nt					
Are all cord, cable and raceway connections intact and secure? In wet or damp locations, are electrical tools and equipment appropriate for the use or location or otherwise protected? Is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls) determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come in contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Are all security and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, pluga or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor in excess of the motor in excess of tw	Are all cord, cable and raceway connections intact and secure? In twet or damp locations, are electrical tools and equipment appropriate for the use or location or otherwise protected? Is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, flutures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is not a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hy rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which occause probably injury from inad) in nt					
protected? Is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls) determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come in contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting means always opened before fuses are replaced? Are all disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and sale operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, pluga or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor ip rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor located within sight of its controller or the controller disconnecting means capable of bein	protected? Is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are all disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are all enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circu when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hy rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which occause probably linjury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor is e) in nt					
□ is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls) determined before digging, drilling or similar work is begun? □ Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come in contact with energized parts of equipment, fixtures or circuit conductors? Is real disconnecting switches and circuit breakers labeled to Indicate their use or equipment served? Are all disconnecting means always opened before fuses are replaced? O all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor closated within sight of its controller or the controller disconne	Is the location of electrical power lines and cables (overhead, underground, underfloor, other side of walls determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are electrical switches for electrical motors in excess of two horsepower, capable of opening the circu when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to decrease of the motor in prating). Is low voltage protection provided in the control device of motors driving machines or equipment, which cocause probably injury from inadvertent starting? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting mean	in nt					
determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come in contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are all disconnecting means always opened before fuses are replaced? Are all clectrical raceways and enclosures securely fastened in place? Are all electrical parts of electrical dircuits and equipment guarded against accidental contact by approved cabinets or enclosures? Are all energized parts of electrical dircuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are described enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor fisconnecting switch or circuit breaker located within sight of the motor control device? Is each motor fisconnecting switch or circuit breaker located within sight of the motor is serves? Are engleyees who regularly work on or aroun	determined before digging, drilling or similar work is begun? Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hip rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which cocause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the	in nt					
Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come in contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and sale operations and maintenance? Are all energized parts of electrical conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor disconnecting switch or circuit breaker located within sight of the motor is serves? Are employees who	 □ Are metal measuring tapes, ropes, handlines or similar devices with metallic thread woven into the fabric prohibited where they could come in contact with energized parts of equipment or circuit conductors? □ Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, fixtures or circuit conductors? □ Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? □ Are disconnecting means always opened before fuses are replaced? □ Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? □ Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? □ Are electrical switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to cause probably injury from inadvertent starting? □ Is low voltage protection provided in the control device of motors driving machines or equipment, which cocause probably injury from inadvertent starting? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a se	nt d					
prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come in contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are all disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor in prating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Are employ	prohibited where they could come in contact with energized parts of equipment or circuit conductors? Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit reand safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are ellectrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cover or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hprating). Is low voltage protection provided in the control device of motors driving machines or equipment, which concuse probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmon	nt d					
□ Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come in contact with energized parts of equipment, fixtures or circuit conductors? □ Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? □ Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? □ Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and sale operations and maintenance? □ Are all unused openings (including condult knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instruc	 Is the use of metal ladders prohibited in area where the ladder or the person using the ladder could come contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circu when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to a excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which occause probably injury from inadvertent starting? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? Are employees wh	nt d					
contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are all disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hy rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause grobably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor peach motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energ	contact with energized parts of equipment, fixtures or circuit conductors? Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circumbent the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which concurred the provided in the control device of motors driving machines or equipment, which concurred in the control located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts	nt d					
Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor floate protection provided in the controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods?	 □ Are all disconnecting switches and circuit breakers labeled to indicate their use or equipment served? □ Are disconnecting means always opened before fuses are replaced? □ Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? □ Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circumbent he motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hp rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which coause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmon	d					
Are disconnecting means always opened before fuses are replaced? □ Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? □ Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hy rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor device? □ Is each motor disconnecting switch or circuit breaker located within sight of the controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the car	Are disconnecting means always opened before fuses are replaced? Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circumbent he motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to device of two horsepower provided in the control device of motors driving machines or equipment, which concurred the motor is placed in the control device of motors driving machines or equipment, which concurred the motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE	d					
 □ Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipment and enclosures? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all electrical parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? □ Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Is each motor is a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor disconnecting switch or circuit breaker located within sight of the motor disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or i	 □ Do all interior wiring systems include provisions for grounding metal parts of electrical raceways, equipme and enclosures? □ Are all electrical raceways and enclosures securely fastened in place? □ Are all electrical caceways and enclosures securely fastened in place? □ Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? □ Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circumbent of the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hip rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which cocause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the motor? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE 	d					
and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hor rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Ar	and enclosures? Are all electrical raceways and enclosures securely fastened in place? Are all electrical raceways and enclosures securely fastened in place? Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circulate when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to conceve second the motor hor rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which concause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum	d					
 □ Are all energized parts of electrical circuits and equipment guarded against accidental contact by approved cabinets or enclosures? □ Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.)	 □ Are all energized parts of electrical circuits and equipment guarded against accidental contact by approve cabinets or enclosures? □ Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cover or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circumbent of the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hp rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which concause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 						
cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor in prating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the r	cabinets or enclosures? Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circulate when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hip rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which concause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
 Is sufficient access and working space provided and maintained about all electrical equipment to permit ready and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor in prating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are these areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels	 □ Is sufficient access and working space provided and maintained about all electrical equipment to permit re and safe operations and maintenance? □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circu when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hp rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which co cause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 	ady					
and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees who regularly work on or around energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have engineering controls been used to reduce excessive noise	and safe operations and maintenance? Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circulation when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hpirating). Is low voltage protection provided in the control device of motors driving machines or equipment, which concause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum	ady					
 □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels being measured using a sound level meter or an octave band analyzer and records being kept? □ Have engineering controls been used to reduce excessive noise levels?	 □ Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs or plates? □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circular when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hp rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which concause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 						
appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have engineering controls been used to reduce excessive noise levels? Where engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of pers	appropriate covers, plugs or plates? Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting cov or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circulation when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which colouse probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covers or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have engineering controls been used to reduce excessive noise levels? Where engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection?	 □ Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight-fitting covor plates? □ Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circulation when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to excess of the motor hp rating). □ Is low voltage protection provided in the control device of motors driving machines or equipment, which concause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 						
or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circuit when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	or plates? Are disconnecting switches for electrical motors in excess of two horsepower, capable of opening the circular when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to dexcess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which cocause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum	ers					
when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to or in excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	when the motor is in a stalled condition, without exploding? (Switches must be horsepower rated equal to dexcess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which co cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	 excess of the motor hp rating). Is low voltage protection provided in the control device of motors driving machines or equipment, which co cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum	it					
 Is low voltage protection provided in the control device of motors driving machines or equipment, which could cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noi se levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA? 	 □ Is low voltage protection provided in the control device of motors driving machines or equipment, which co cause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 	r in					
cause probably injury from inadvertent starting? Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	 □ cause probably injury from inadvertent starting? □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 	1 . 1					
□ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) □ Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? □ Have you tried isolating noisy machinery from the rest of your operation? □ Have engineering controls been used to reduce excessive noise levels? □ Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? □ Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? □ Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	 □ Is each motor disconnecting switch or circuit breaker located within sight of the motor control device? □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 	ula					
□ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? ■ NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) □ Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? □ Have you tried isolating noisy machinery from the rest of your operation? □ Have engineering controls been used to reduce excessive noise levels? □ Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? □ Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? □ Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	 □ Is each motor located within sight of its controller or the controller disconnecting means capable of being locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? □ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 						
locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	locked in the open position or is a separate disconnecting means installed in the circuit within sight of the motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of trating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
motor? Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of the rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	motor? ☐ Is the controller for each motor in excess of two horsepower, rated in horsepower equal to or in excess of t rating of the motor is serves? ☐ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? ☐ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE ☐ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	rating of the motor is serves? Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
 □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) □ Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? □ Have you tried isolating noisy machinery from the rest of your operation? □ Have engineering controls been used to reduce excessive noise levels? □ Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? □ Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? □ Is the training repeated annually for employees exposed to continuous noise above 85 dBA? 	 □ Are employees who regularly work on or around energized electrical equipment or lines instructed in the cardiopulmonary resuscitation (CPR) methods? □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 	пе					
cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	cardiopulmonary resuscitation (CPR) methods? Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	 □ Are employees prohibited from working alone on energized lines or equipment over 600 volts? NOISE □ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum 						
Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	NOISE Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum allowable levels for intermittent or impact noise, see Title 8, Section 5097.) Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	☐ Are there areas in the workplace where continuous noise levels exceed 85 dBA? (To determine maximum						
allowable levels for intermittent or impact noise, see Title 8, Section 5097.) □ Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? □ Have you tried isolating noisy machinery from the rest of your operation? □ Have engineering controls been used to reduce excessive noise levels? □ Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? □ Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? □ Is the training repeated annually for employees exposed to continuous noise above 85 dBA?							
allowable levels for intermittent or impact noise, see Title 8, Section 5097.) □ Are noise levels being measured using a sound level meter or an octave band analyzer and records being kept? □ Have you tried isolating noisy machinery from the rest of your operation? □ Have engineering controls been used to reduce excessive noise levels? □ Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? □ Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? □ Is the training repeated annually for employees exposed to continuous noise above 85 dBA?							
Are not se levels being measured using a sound level meter or an octave band analyzer and records being kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	allowable levels for intermittent or impact noise, see title 8. Section 5097)						
kept? Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?							
 Have you tried isolating noisy machinery from the rest of your operation? Have engineering controls been used to reduce excessive noise levels? Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA? 							
 ☐ Have engineering controls been used to reduce excessive noise levels? ☐ Where engineering controls are determined not feasible, are administrative controls (i.e. worker rotation) being used to minimize individual employee exposure to noise? ☐ Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? ☐ Is the training repeated annually for employees exposed to continuous noise above 85 dBA? 	·						
used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?							
used to minimize individual employee exposure to noise? Is there an ongoing preventive health program to educate employees in safe levels of noise and exposure, effects of noise on their health, and use of personal protection? Is the training repeated annually for employees exposed to continuous noise above 85 dBA?							
effects of noise on their health, and use of personal protection? ☐ Is the training repeated annually for employees exposed to continuous noise above 85 dBA?	used to minimize individual employee exposure to noise?						
Is the training repeated annually for employees exposed to continuous noise above 85 dBA?							
_							
THE WAY WELL TO BE WOOLD BOLD TO BE TO MAKE VALUE AND ADDITIONAL PROPERTY AND ADDITIONAL ADDITIONAL AND ADDITIONAL ADDITIONAL ADDITIONAL ADDITIONAL AND ADDITIONAL ADDITIO							
· • •	Have work areas where noise levels make voice communication between employees difficult been identified and posled?						

	Is approved hearing protective equipment (noise attenuating devices) available to every employee working in areas where continuous noise levels exceed 85 dBA? If you use ear protectors, are employees properly fitted and instructed in their use and care? Are employees exposed to continuous noise above 85 dBA given periodic audiometric testing to ensure that you have an effective hearing protection system?				
	FUELING				
	Is it prohibited to fuel an internal combustion engine with a flammable liquid while the engine is running? Are fueling operations done in such a manner that likelihood of spillage will be minimal? When spillage occurs during fueling operations, is the spilled fuel cleaned up completely, evaporated, or other measures taken to control vapors before restarting the engine? Are fuel tank caps replaced and secured before starting the engine? In fueling operations is there always metal contact between the container and fuel tank? Are fueling hoses of a type designed to handle the specific type of fuel? Is it prohibited to handle or transfer gasoline in open containers? Are open lights, open flames, or sparking or arcing equipment prohibited near fueling or transfer of fuel operations? Is smoking prohibited in the vicinity of fueling operations? Are fueling operations prohibited in building or other enclosed areas that are not specifically ventilated for this purpose? Where fueling or transfer of fuel is done through a gravity flow system, are the nozzles of the self-closing type?				
	IDENTIFICATION OF PIPING SYSTEMS				
	When nonpotable water is piped through a facility, are outlets or taps posted to alert employees that it is unsafe and not to be used for drinking, washing or other personal use? When hazardous substances are transported through above ground piping, is each pipeline identified at points where confusion could introduce hazards to employees? When pipelines are identified by color painting, are all visible parts of the line so identified? When pipelines are identified by color painted bands or tapes, are the bands or tapes located at reasonable intervals and at each outlet, valve or connection? When pipelines are identified by color, is the color code posted at all locations where confusion could introduce hazards to employees? When the contents of pipelines are identified by name or name abbreviation, is the information readily visible on the pipe near each valve or outlet? When pipelines carrying hazardous substances are identified by tags, are the tags constructed of durable materials, the message carried clearly ad permanently distinguishable and are tags installed at each valve or outlet? When pipelines are heated by electricity, steam or other external source, are suitable warning signs or tags placed at unions, valves, or other serviceable parts of the system?				
	Is there safe clearance for equipment through aisles and doorways?				
	Are aisleways designated, permanently marked, and kept clear to allow unhindered passage?				
_	Are motorized vehicles and mechanized equipment inspected daily or prior to use?				
	Are vehicles shut off and brakes set prior to loading or unloading?				
	dunnage sufficient to provide stability? Are dock boards (bridge plates) used when loading or unloading operations are taking place between vehicles and docks?				
	Are trucks and trailers secured from movement during loading and unloading operations?				

	Are dock plates and loading ramps constructed and maintained with sufficient strength to support imposed loading?			
	Are hand trucks maintained in safe operating condition?			
	Are chutes equipped with sideboards of sufficient height to prevent the materials being handled from falling off?			
	Are chutes and gravity roller sections firmly placed or secured to prevent displacement?			
	At the delivery end of rollers or chutes, are provisions made to brake the movement of the handled materials.			
	Are pallets usually inspected before being loaded or moved?			
L	Are hooks with safety latches or other arrangements used when hoisting materials so that slings or load attachments won't accidentally slip off the hoist hooks?			
	Are securing chains, ropes, chockers or slings adequate for the job to be performed?			
	When hoisting material or equipment, are provisions made to assure no one will be passing under the			
_	suspended loads?			
L	Are Material Safety Data Sheets available to employees handling hazardous substances?			
	TRANSPORTING EMPLOYEES & MATERIALS			
П	Do amplayage who aparate vahiolog on public theroughfores have valid aparateria licenses?			
	Do employees who operate vehicles on public thoroughfares have valid operator's licenses?			
لسسا	When seven or more employees are regularly transported in a van, bus or truck, is the operator's license appropriate for the class of vehicle being driven?			
П	Is each van, bus or truck used regularly to transport employees, equipped with an adequate number of seats?			
	is each van, bus of truck used regularly to transport employees, equipped with an adequate number of seats?			
	When employees are transported by truck, are provision provided to prevent their falling from the vehicle?			
	Are vehicles used to transport employees, equipped with lamps, brakes, horns, mirrors, windshields and turn			
	signals in good repair?			
	Are transport vehicles provided with handrails, steps, stirrups or similar devices, so placed and arranged that			
	employees can safely mount or dismount?			
	Are employee transport vehicles equipped at all times with at least two reflective type flares?			
	Is a full charged fire extinguisher, in good condition, with at least 4 B:C rating maintained in each employee			
_	transport vehicle?			
Ш	When cutting tools with sharp edges are carried in passenger compartments of employee transport vehicles,			
Ш	are they placed in closed boxes or containers which are secured in place?			
Ш	Are employees prohibited from riding on top of any load, which can shift, topple, or otherwise become			
	unstable?			
	CONTROL OF HARMFUL SUBSTANCES BY VENTILATION			
	Is the volume and velocity of air in each exhaust system sufficient to gather the dusts, fumes, mists, vapors or			
	gases to be controlled, and to convey them to a suitable point of disposal?			
Ц	Are exhaust inlets, ducts and plenums designed, constructed, and supported to prevent collapse or failure of any part of the system?			
П	Are clean-out ports or doors provided at intervals not to exceed 12 feet in all horizontal runs of exhaust ducts?			
	The older out ports of doors provided at intervals hot to exceed 12 feet in all horizontal rans of exhaust ducts:			
	Where two or more different type of operations are being controlled through the same exhaust system, will the			
	combination of substances being controlled, constitute a fire, explosion or chemical reaction hazard in the			
duct?				
	Is adequate makeup air provided to areas where exhaust systems are operating?			
Is the intake for makeup air located so that only clean, fresh air, which is free of contaminates, will enter				
work environment? Where two or more ventilation systems are serving a work area, is their operation such that one will not				
	the functions of the other?			

	being easily cleaned and disinfected? Are employees prohibited from interchanging personal protective clothing or equipment, unless it has been properly cleaned? Are machines and equipment, which processes, handle or apply materials that could be injurious to employees, cleaned and/or decontaminated before being overhauled or placed in storage? Are employees prohibited from smoking or eating in any area where contaminates are present that could be injurious if ingested? When employees are required to change from street clothing into protective clothing, is a clean changeroom with separate storage facility for street and protective clothing provided? Are employees required to shower and wash their hair as soon as possible after a known contact has occurred with a carcinogen? When equipment, materials, or other items are taken into or removed from a carcinogen regulated area, is it
	done in a manner that will not contaminate non-regulated areas or the external environment?
	TIRE INFLATION
	Where tires are mounted and/or inflated on drop center wheels is a safe practice procedure posted and enforced?
	Where tires are mounted and/or inflated on wheels with split rims and/or retainer rings is a safe practice procedure posted and enforced?
	Does each tire inflation hose have a clip-on chuck with at least 24 inches of hose between the chuck and an in- line hand valve and gauge?
	Does the tire inflation control valve automatically shut off the airflow when the valve is released?
	Is a tire restraining device such as a cage, rack or other effective means used while inflating tires mounted on split rims, or rims using retainer rings?
Ц	Are employees strictly forbidden from taking a position directly over or in front of a tire while it's being inflated?
	EMERGENCY ACTION PLAN
	Are you required to have an emergency action plan? Does the emergency action plan comply with requirements of T8CCR 3220(a)? Have emergency escape procedures and routes been developed and communicated to all employers? Do employees, who remain to operate critical plant operations before they evacuate, know the proper
	procedures? Is the employee alarm system that provides a warning for emergency action recognizable and perceptible
	above ambient conditions? Are alarm systems properly maintained and tested regularly?
	Is the emergency action plan reviewed and revised periodically? Do employees now their responsibilities:
	For reporting emergencies?
	During an emergency?
	For conducting rescue and medical duties?
	INFECTION CONTROL
	Are employees potentially exposed to infectious agents in body fluids? Have occasions of potential occupational exposure been identified and documented? Has a training and information program been provided for employees exposed to or potentially exposed to blood and/or body fluids? Have infection control procedures been instituted where appropriate, such as ventilation, universal precautions, workplace practices, and personal protective equipment?
	Are employees aware of specific workplace practices to follow when appropriate? (Hand washing, handling sharp instruments, handling of laundry, disposal of contaminated materials, reusable equipment.)

	the first control from					
	Is the necessary equipment (i.e. mouthpieces, resuscitation bags, and other ventilation devices) provided for administering mouth-to-mouth resuscitation on potentially infected patients?					
	Are facilities/equipment to comply with workplace practices available, such as hand-washing sinks, biohazard					
	tags and labels, needle containers, detergents/disinfectants to clean up spills? Are all equipment and environmental and working surfaces cleaned and disinfected after contact with blood or					
	potentially infectious materials? Is infectious waste placed in closable, leak proof containers, bags or puncture-resistant holders with proper					
	labels? Has medical surveillance including HBV evaluation, antibody testing and vaccination been made available to					
	potentially exposed employees? Training on universal precautions?					
	Training on personal protective equipment?					
	Training on workplace practices, which should include blood drawing, room cleaning, laundry handling, clean up of blood spills?					
	Training on needlestick exposure/management?					
	Hepatitis B vaccinations?					
	ERGONOMICS					
	Can the work be performed without eyestrain or glare to the employees?					
	Does the task require prolonged raising of the arms?					
	Are there pressure points on any parts of the body (wrists, forearms, back of thighs)?					
	Can the work be done using the larger muscles of the body?					
	Can the work be done without twisting or overly bending the lower back?					
	Are there sufficient rest breaks, in addition to the regular rest breaks, to relieve stress from repetitive-motion					
_	tasks?					
Ш	Are tools, instruments and machinery shaped, positioned and handled so that tasks can be performed					
	comfortably? Are all pieces of furniture adjusted, positioned and arranged to minimize strain on all parts of the body?					
	VENTILATION FOR INDOOR AIR QUALITY					
	Does your HVAC system provide at least the quantity of outdoor air required by the State Building Standards					
П	Code, Title 24, Part 2 at the time the building was constructed?					
	Is the HVAC system inspected at least annually, and problems corrected? Are inspection records retained for at least 5 years?					
Ч	Are inspection records retained for at least 5 years?					
	CRANECHECKLIST					
	Are the cranes visually inspected for defective components prior to the beginning of any work shift?					
	Are all electrically operated cranes effectively grounded?					
	Is a crare preventive maintenance program established?					
	Is the load chart clearly visible to the operator?					
	Are operating controls clearly identified?					
	Is a fire extinguisher provided at the operator's station?					
	☐ is the raled capacity visibly marked on each crane?					
	☐ Is an audible warning device mounted on each crane?					
	Is sufficient illumination provided for the operator to perform the work safely?					
	Are cranes of such design, that the boom could fall over backward, equipped with boomstops?					
	Does each crane have a certificate indicating that required testing and examinations have been performed?					
П	Are crara inspection and maintenance records maintained and available for inspection?					

		•	
		•	
•			
	÷		